

Republic of the Philippines UNIVERSITY OF RIZAL SYSTEM

Tanay, Rizal

Tel/Fax 653-2860 email: urs.spmo@gmail.com

BIDS AND AWARDS COMMITTTEE

SUPPLEMENTAL BID BULLETIN NO. 1

Supply, Delivery and Installation of Air-conditioning Units for RDEP Training Center and Fishery Products Innovation and Training Center Date: September 21, 2018

This Supplemental Bid Bulletin No. 1 is issued to modify or amend items in the Bid Documents. This shall form an integral part of the Bid Documents.

Section VII. Technical Specifications

Lot 1

2. Air conditioner, 2 units and complies with the following minimum specification:		Revision
2.1	Super Inverter Split type	Super Inverter Split type
2.2	13.8 or better EER	13.8 kj/hr or better EER
2.3	1.5HP	1.5HP
2.4	Wall mounted	Wall mounted
2.5	Indoor unit 220-230V 60Hz	Indoor unit 220-230V 60Hz
2.6	Ozone friendly R410A refrigerant	Ozone friendly R410A refrigerant
2.7	Include product brochure	Include product brochure
2.8	Brand new with one (1) year on-site	Brand new with one (1) year on-
	warranty on parts & labor	site warranty on parts & labor

Lot 2

2. Air conditioner, 3 units and complies with the following minimum specification:		Revision
2.1	Super Inverter Split type	Super Inverter Split type
2.2	13.8 or better EER	13.8 kj/hr or better EER
2.3	1.5HP	1.5HP
2.4	Wall mounted	Wall mounted
2.5	Indoor unit 220-230V 60Hz	Indoor unit 220-230V 60Hz
2.6	Ozone friendly R410A refrigerant	Ozone friendly R410A refrigerant

2.7	Include product brochure	Include product brochure
2.8	Including delivery & installation to	Including delivery & installation
	URS Cardona Campus	to URS Cardona Campus
2.9	Brand new with one (1) year on-site	Brand new with one (1) year on-
	warranty on parts & labor	site warranty on parts & labor
3. Air conditioner, 4		
units and complies		
with the following		
minimum		
specification:		
3.1	Super Inverter Split type	Super Inverter Split type
3.2	13.8 or better EER	13.8 kj/hr or better EER
3.3	2HP	2HP
3.4	Wall mounted	Wall mounted
3.5	Indoor unit 220-230V 60Hz	Indoor unit 220-230V 60Hz
3.6	Ozone friendly R410A refrigerant	Ozone friendly R410A refrigerant
3.7	Include product brochure	Include product brochure
3.8	Including delivery & installation to	Including delivery & installation
	URS Cardona Campus	to URS Cardona Campus
3.9	Brand new with one (1) year on-site	Brand new with one (1) year on-
	warranty on parts & labor	site warranty on parts & labor

For guidance and information of all concerned.

NELSON'S GONZALES, Ed D

Chairperson, Bids & Awards Committee